



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001





No. F.6/DFS/MS/School/2025/SZ/ 1247

Dated: 13 / 10 / 2025

FIRE SAFETY CERTIFICATE

Certified that building of Delhi English Academy School located at Dhool Siras, Sector-26, Dwarka, New Delhi-110077, comprised of 2 Block: Ground + 01 upper floor & Ground floor only, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2022/School/287 dated 16/03/2022. The premise was re-inspected by the officer concerned of this department on 26/09/2025 in the presence of Sh. Rakesh Sharma (Principal) and observed addition of two upper floors in existing building of G+1 Block. Now, the school building comprised of ground plus three upper floor & ground floor only have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school premise/building is fit for occupancy class "Educational Group B" with effect from 13/ 10 / 2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13 / 10 / 2025 at New Delhi by


(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service


Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Principal, Delhi English Academy School located at Dhool Siras, Sector-26, Dwarka, New Delhi-110077
3. The Commissioner, MCD, 9th Floor, Dr. SPM Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in